

# ATTESTATION OF CONFORMITY

Issued to: Selec Controls Pvt. Ltd.  
EL-27/1, Electronic Zone, TTC Industrial Area, MIDC, Mahape,  
Navi Mumbai – 400 710,  
India

For the product: Modular Residual Current Device

Trade name: Selec

Type/Model: ELRA2M2-1-230V-FS-CE-RoHS (Adjustable 30mA to 30A)

Ratings:  $I_{\Delta n}$  from 30 mA fixed, 100 mA fixed, 300 mA fixed, 30 mA - 30 A selectable,  
time delay from 0 s – 9 s selectable  
 $U_s$ : 110, 230 Vac

Subject: Type tests

Requirements: IEC 60947-2:2016  
Clauses MI (excluding M8.6), MIII, MIV

Remarks: EMC tests have only been performed on the 230 V model of the ELRA2M2-1-230V-  
FS-CE-RoHS

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in report no. 2244152.50-INC, dated 8 April 2020.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 8 April 2020

Number: 2244152.01-AOC

DEKRA Certification B.V.



H.L. Schendstok  
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed